

PROVISIONAL  
HAZARDOUS MATERIALS UNDERGROUND STORAGE PERMIT  
COUNTY OF LOS ANGELES  
DEPARTMENT OF PUBLIC WORKS  
WASTE MANAGEMENT DIVISION  
2250 ALCAZAR STREET  
LOS ANGELES, CALIFORNIA 90033

PERMIT NO. 1931EXPIRATION DATE DEC 01 1987

PERMISSION IS HEREBY GRANTED UNDER LACC TITLE 11, DIVISION 4 TO:

NU CAR PREP SYSTEM INC  
12140 E SLAUSON AVE  
SANTA FE SPRINGS CA 90670

005805-1H

<<<<<<< FILE NUMBER  
<<<<<<< PERMITTEE

RE: 12140 E SLAUSON AVE

&lt;&lt;&lt;&lt;&lt;&lt;&lt; FACILITY ADDRESS

TO STORE HAZARDOUS MATERIALS IN UNDERGROUND TANK(S) LOCATED AT THE FACILITY ABOVE.

NUMBER OF PERMITTED TANKS: 7

THIS PROVISIONAL PERMIT IS SUBJECT TO THE FOLLOWING REQUIREMENTS:

PART A — GENERAL CONDITIONS AND LIMITATIONS (ATTACHED).

PART B — AUTHORIZED HAZARDOUS MATERIAL STORAGE TANKS (ATTACHED).

PART C — SPECIFIC CONDITIONS AND LIMITATIONS:

1. THE PERMITTEE SHALL SUBMIT FOR APPROVAL AND IMPLEMENT A LEAK DETECTION PROGRAM (LDP) AND A TANK MONITORING PROGRAM (TMP) PREPARED IN ACCORDANCE WITH "UNDERGROUND STORAGE OF HAZARDOUS MATERIALS - GUIDELINES FOR EXISTING FACILITIES, OCTOBER 1986."
2. THE FOLLOWING TIME SCHEDULE SHALL APPLY TO SUBMITTALS REQUIRED BY THIS PROVISIONAL PERMIT:
  - a. PERMIT FEE DUE BY (SEE INVOICE) To be billed
  - b. TANK INTEGRITY TEST RESULTS DUE BY SEP 01 1987
  - c. PROPOSALS FOR LDP AND TMP DUE BY SEP 01 1987
3. PERMIT EFFECTIVE DATE 12/11/85  
NOTE: THE EFFECTIVE DATE IS DETERMINED BY ORIGINAL DATE OF PERMIT APPLICATION.

PART D — SPECIAL CONDITIONS AND LIMITATIONS ATTACHED. YES [ ] NO [X]

This Provisional Permit is valid only for the continued operation of tanks providing suitable storage and expires six (6) months from the date of issue. Permittee has until the expiration date to complete an approved LDP and to install and be in compliance with an approved TMP. Upon full compliance with the approved LDP and TMP and all other conditions and limitations, this Provisional Permit will be replaced by a full term Operational Permit for the remainder of the unexpired five (5) year term from the effective date unless otherwise noted in Part D above.

T. A. TIDEMANSON  
DIRECTOR OF PUBLIC WORKS

BY [Signature]  
WASTE MANAGEMENT DIVISION

JUN 01 1987

PP801 10/86

# HAZARDOUS MATERIALS UNDERGROUND STORAGE TANK PERMIT

## PART A — GENERAL CONDITIONS AND LIMITATIONS

### TERM OF PERMIT

1. The combined provisional and full term operational permits shall be valid for a maximum period of five (5) years from the effective date. However, if the Department of Public Works (DPW) finds that the life expectancy of a facility is less than five (5) years, the DPW may adjust the term of the permit to reflect such a condition.

### FEES

2. All fees shall be due and payable on the billing date established by the DPW. Fees not paid within 30 calendar days from the billing date shall be considered delinquent. Delinquent fees shall be subject to a 10 percent penalty fee for each 30 day period beyond the billing date that the fee is due. Permits for which the annual permit fee installment is delinquent for 90 days or more are subject to suspension.

### REPORTS AND RECORDS

3. At least annually and due by the anniversary of the effective date of this permit, a written report must be submitted to the Department of Public Works, Waste Management Division, P.O. Box 4089 Terminal Annex, Los Angeles, CA 90051 detailing (but not limited to) the following:
  - a. Any changes in the type of hazardous materials stored within the facility.
  - b. Any changes in the uses of the underground facility.
  - c. Changes or modifications to monitoring procedure.
  - d. A detailed account of any unauthorized discharges, and the remedial measures employed.
  - e. Any modifications to the facility except for routine required maintenance.

In the event there has been no change of operation nor unauthorized release, a negative declaration to that effect may be submitted.

The report or negative declaration shall be certified by the permittee or an authorized representative who is responsible for operations at the facility.

This report is required by local agencies to satisfy Section 25286(c) of the State of California Health and Safety Code. A report form will be made available to owners and operators to comply with this requirement. The report shall be delinquent 30 days after its due date and as such may result in suspension or revocation of the permit.

4. Every permittee shall provide testing, monitoring (if applicable), and inspections in compliance with this permit and shall maintain records adequate to demonstrate compliance therewith.
5. All required records shall be maintained by the permittee and made available for inspection for a period of time not less than three (3) years from the date of the required annual report for the year during which the testing, monitoring or inspection was performed. Said records shall be made available to the DPW, County Health Officer or Forester and Fire Warden during normal working hours and at any time upon reasonable notice.

### RENEWALS AND EXTENSIONS

6. If this is a provisional permit, it may be extended to a maximum of one (1) additional year upon written application stating the reasons for such a request and upon approval by the Director of Public Works.
7. Every application for the renewal of an operational permit or extension of a provisional permit shall be made at least 30 days prior to the expiration date of such permit. If a timely application for renewal has been submitted, the permit shall remain in effect until the DPW has made a decision and any administrative appeal has been exhausted.

### APPEALS

8. Any person dissatisfied with the decision of the DPW may appeal the decision, in writing, to the Appeals Board, setting forth with particularity the ground or grounds for the appeal. Such appeal shall be submitted within 30 days after notice of the decision has been given.

### ADDITIONAL APPROVALS AND REPAIRS

9. Additional approvals shall be required for any of the following actions:
  - a. Tank repair.
  - b. Modifications.
  - c. Change or addition of hazardous materials stored.
  - d. Change of approved monitoring system.
10. Procedures for an application for a permit shall also apply to an application for an additional approval. Each application for an additional approval shall be accompanied by the appropriate fee and supporting information.
11. Any substantial modification or repair of a facility other than minor repairs or emergency repairs shall be in accordance with plans to be submitted to the DPW as an additional approval.
12. Permittee shall carry out routine maintenance, ordinary upkeep and minor repairs in a careful and safe manner. No permit will be required for such maintenance, upkeep and repairs.
13. Permittee may make emergency repairs to a facility in advance of seeking an additional approval whenever an immediate repair is required to prevent or contain an unauthorized discharge or to protect the integrity of the containment. However, within five (5) working days after such emergency repairs have been started, permittee shall seek additional approval by submitting drawings or other information adequate to describe the repairs to the DPW.

### CLOSURES, DECONTAMINATION AND NEW CONSTRUCTION

14. Replacement of tanks at an existing facility shall be considered a closure of the tanks to be replaced and a new installation of tanks, and all fees shall be assessed accordingly.
15. No tank shall be abandoned. Tanks which are temporarily out of service, and are intended to be returned to use, must continue to be monitored and inspected. Any tank which is not being monitored and inspected must be closed or removed in a manner approved by the DPW.
16. Prior to any permanent or temporary closures being initiated, an Application for Closure form, the appropriate fee and required supporting information shall be filed with the DPW.
17. Plans for the decontamination of a facility shall be submitted to the DPW for approval no later than 30 days before the commencement of such operations. Other agencies having jurisdiction shall also be notified. These agencies include the California Regional Water Quality Control Board, the Los Angeles County Department of Health Services and the South Coast Air Quality Management District.
18. The installation of a new tank shall require submittal to the DPW of an application for new construction, the appropriate new construction plan clearance fee and supporting information as required by the DPW.

### TRANSFER

19. A Hazardous Materials Underground Storage Permit may be transferred to a new owner of the same facility provided:
  - a. The new owner accepts full responsibility for all obligations under this permit at the time of the transfer of the facility.
  - b. The transfer shall be documented on a form provided by the DPW within 30 days of transfer of ownership.
  - c. The appropriate fee is paid.

PART B — TANK DATA

HAZARDOUS MATERIALS UNDERGROUND STORAGE PERMIT NO. 1931

AUTHORIZED HAZARDOUS MATERIAL STORAGE TANKS

<u>TANK NUMBER</u>	<u>CAPACITY (GALLONS)</u>	<u>CONTENTS</u>
1	3,000	Unleaded /
2	3,000	Unleaded /
3	10,000	Unleaded /
10	550	Motor Oil SAE 30✓
11	550	Empty
12	550	Empty
9	550	Automatic transmission fluid